



NOTES:

1. ALL MATERIALS TO BE ALUMINUM 6061-T6 ALLOY.
2. WELD ALL INTERSECTIONS.
3. FASTEN TO CONCRETE STRUCTURE WITH 3/8 in. x 3 in. STAINLESS STEEL CONCRETE WEDGE ANCHORS MINIMUM OF (4).
4. WIDTH OF 1/4 in. FLAT STOCK = 2 x BAR DIAMETER.
5. RACK I.D. = DIAMETER (D) - 1/2 in.
6. OPTIONAL - 10g STAINLESS STEEL WIRE MESH WITH 1 in. GRID TO COVER RACK.
7. OPTIONAL MOUNTING TABS PARALLEL WITH 1/4 in. FLAT STOCK ARE AVAILABLE FOR MOUNTING RACK TO PIPE O.D. (FLUSH MOUNT SHOWN).

TRASH RACK INFORMATION	
RACK DIAMETER O.D. (D)	
BAR DIAMETER	
BAR CENTERLINE SPACING	
MOUNTING TAB LENGTH (L)	
STRUCTURE OPENING DIA.	
FLUSH OR PIPE MOUNT?	
FASTENERS (QTY)	
WIRE MESH?	
NOTES:	

This CAD file and drawing is the property of Effluent Design & Fabrication, LLC. It is intended for the named recipient. Unauthorized reproduction, disclosure, or distribution is strictly prohibited.

	PO Box 2273 Flemington, NJ 08822
	Phone: 908.458.9220 FAX: 908.458.9930
PROJECT: ALUMINUM CIRCULAR SERIES AC RACK	FILE #: _____
	DATE: _____
	SCALE: _____
	DRAWN BY: _____