


1/4 in x 2 in ALUMINUM
FLAT STOCK (4 SIDES)

NOTES:

1. ALL MATERIALS TO BE ALUMINUM 6061 T-6 ALLOY.
2. WELD ALL INTERSECTIONS.
3. FASTEN TO CONCRETE STRUCTURE WITH 3/8 in x 3 in STAINLESS STEEL CONCRETE WEDGE ANCHORS AT 24 in MAX SPACING. MINIMUM OF (4).
5. 1/4 in x 4 in ALUMINUM UNION PLATE USED TO JOIN VERTICAL MEMBERS AS REQUIRED.
6. HEIGHT = $\text{NARROWER DIMENSION OF (W) OR (D)} \times 0.866$
TOLERANCE = ± 1 in.
7. OPTIONAL - 10g STAINLESS STEEL WIRE MESH WITH 1 in GRID TO COVER RACK.
8. TO DETERMINE WIDTH & DEPTH TO CENTERLINE OF BARS - STRUCTURE I.D. ROUNDED UP TO NEAREST INCREMENT OF REQUIRED BAR CENTERLINE SPACING. EX: 48 in STRUCTURE I.D WITH 6 in CENTERLINE REQUIRED = 54 in

This CAD file and drawing is the property of Effluent Design & Fabrication, LLC. It is intended for the named recipient. Unauthorized reproduction, disclosure, or distribution is strictly prohibited.

TRASH RACK INFORMATION	
BAR DIAMETER (1/2" OR 3/4")	
BAR CENTERLINE SPACING	
RACK WIDTH TO BAR CL (W)	
RACK DEPTH TO BAR CL (D)	
RACK HEIGHT (H)	
FASTENERS (QTY)	
WIRE MESH?	
STRUCTURE WIDTH I.D.	
STRUCTURE DEPTH I.D.	
STRUCT. WALL THICKNESS	
NOTES:	

	6 William Martin Way Flemington, NJ 08822 Phone: 908.458.9220 FAX: 908.458.9930
	PROJECT: ALUMINUM PYRAMID SERIES AP RACK
FILE #: DATE: SCALE: DRAWN BY:	