



1/4 x 2 in FLAT STOCK HINGE ASSEMBLY
WITH ALUMINUM WELD-ON HINGES

1/4 x 2 in FLAT STOCK FOR
HINGES TO WELD TO.

ALUMINUM GRATING
(SEE DETAIL)



GRATING DETAIL

NOTES:

1. GRATING ONLY IS 6063 ALUMINUM ALLOY.
2. ALL OTHER MATERIALS ADDITIONAL TO GRATING SHALL BE 6061-T6 ALUMINUM ALLOY.
3. THE DEPTH (D) OF THIS RACK MUST BE THE SAME AS THE HEIGHT (H).
4. I.D. OF RACK WIDTH = (W) - 4 in.
5. I.D. OF RACK HEIGHT = (H) - 3 in.
6. FASTEN TO CONCRETE STRUCTURE WITH 3/8 in. x 3 in. STAINLESS STEEL CONCRETE WEDGE ANCHORS AT 18 in. MAX. SPACING. MINIMUM OF (2).
7. HINGES ARE ALUMINUM WELD-ON TYPE, 4 in. LONG WITH 3/8 in. STAINLESS PIN SPACED AT 24 in. MAX. SPACING.
8. HINGE ASSEMBLY IS STANDARD, BUT MAY BE ELIMINATED.
9. RACK HAS OPEN BOTTOM AND IS DESIGNED TO REST ON CHANNEL, APRON, OR BASIN BOTTOM.

This CAD file and drawing is the property of Effluent Design & Fabrication, LLC. It is intended for the named recipient. Unauthorized reproduction, disclosure, or distribution is strictly prohibited.

TRASH RACK INFORMATION	
RACK WIDTH O.D. (W)	
RACK HEIGHT I.D. (H)	
RACK DEPTH O.D. (D)	
FASTENERS (QTY)	
HINGES REQUIRED?	
NOTES:	



6 William Martin Way
Flemington, NJ 08822

Phone: 908.458.9220
FAX: 908.458.9930

www.effluentdesignfab.com

PROJECT:
ALUMINUM RECTANGULAR BAR SERIES RBW

FILE #:

DATE:

SCALE:

DRAWN BY: